



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschlüsse • building hardware

TEST CERTIFICATE NO. 19/04-A007-Z3

PfB-Internal-No. 2019-27-0560

Version 1.en

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A2 : 2016 "Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets- German version EN 14351-1:2006 + A2:2016"

Applicant ASAŞ Alüminyum San. ve Tic. A.Ş.
Rüzgarlı Bahçe Mh. Kumlu Sk. No:2
Kavacak - Beykoz - İstanbul
Türkiye

Product type Inward one only turn, one tilt and turn two casement window, PVC, double glazing

Product name 70mm Elegans System Window

Hardware Roto


Sealing EPDM

Dimension Total outside dimensions (W x H) max. 1700 mm x 1500 mm

Classification According to test report No. 19/04-A007-B3 from June 20, 2019:



EN 1026	Air Permeability	EN 12207	Class 4
EN 1027	Water tightness	EN 12208	Class E1650
EN 12211	Resistance to wind load	EN 12210	Class C5/B5



Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016


Dipl. Ing. (FH) Rüdiger Müller
Head of Institute




Yiğit Altuğ
Responsible Official