

Number	21-002357-PR07 (NW-A01-0203-en-04)
Owner	ASAS Alüminyum Sanayi ve Ticaret A.S. Kücücek İstiklal Mah., Kışla Alanı Cad. No: 2-1/1 Akyazi 54400 Sakarya Turkey
Product	Single sash sliding door with fixed sidelight
Designation	System: INOVA NEW GENERATION INSULATED SLIDING SYSTEM Shipping name: uPVC INOVA NEW GENERATION INSULATED SLIDING SYSTEM (TYPE 4)
Details	Manufacturer ASAS Alüminyum Sanayi ve Ticaret A.S., Sakarya; Material Plastic, with reinforcement; Type of opening Sliding; Opening direction To the right (seen from inside); Overall dimensions (W x H) 3100 mm x 2400 mm
Special features	Test sequence.
Result **)	

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: B3

Watertightness according to EN 12208:1999-11



Class: 9A

Operating forces according to EN 13115:2001-07



Class: 1

ift Rosenheim
11.11.2021

Thomas Krichbaumer

Thomas Krichbaumer
Deputy Head of Testing Department
Building Component Testing

Dimitrios Moustakidis

Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 21-002357-PR07 PB-
A01-0203-en-03

Replaces ift-Nachweis: 21-
002357-PR07 NW-A01-0203-en-
03 dated 29.10.2021.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

**) Decision rule: For the conformity assessment, the determined measurement results were assumed to be error-free values.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: F01-E6F98