

Number	21-002357-PR07 (NW 01-A01-03-en-04)
Owner	ASAS Alüminyum Sanayi ve Ticaret A.S. Kücücek İstiklal Mah., Kışla Alanı Cad. No: 2-1/1 Akyazi 54400 Sakarya Turkey
Product	Single sash sliding door with fixed sidelight
Designation	System: INOVA NEW GENERATION INSULATED SLIDING SYSTEM Shipping name: uPVC INOVA NEW GENERATION INSULATED SLIDING SYSTEM (TYPE 4)
Details	Manufacturer ASAS Alüminyum Sanayi ve Ticaret A.S., Sakarya; Material Plastic, with reinforcement; Type of opening Sliding; Opening direction To the right (seen from inside); Overall dimensions (W x H) 3100 mm x 2400 mm
Special features	-/-

Result **)

Operating forces according to EN 13115:2001-07



Class: 1

Mechanical properties according to EN 13115:2001-07



Class: 3

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions (e.g. DIN EN)

Test report: 21-002357-PR07 PB 01-A01-03-en-03

Replaces ift-Nachweis: 21-002357-PR07 NW 01-A01-0203-en-03 dated 29.10.2021.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

**) Decision rule: For the conformity assessment, the determined measurement results were assumed to be error-free values.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

11.11.2021

Thomas Krichbaumer

Thomas Krichbaumer
Deputy Head of Testing Department
Building Component Testing

Dimitrios Moustakidis

Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 4F5-30ACD