

Number	21-002514-PR02 (NW-K20-06-en-02)
Owner	ASAS Alüminyum Sanayi ve Ticaret A.S. Kücücek İstiklal Mah., Kışla Alanı Cad. No: 2-1/1 Akyazi 54400 Sakarya Turkey
Product	Hollow chamber profiles - plastic
Designation	System: uPVC INOVA NEW GENERATION INSULATED SLIDING SYSTEM
Details	Material Polyvinylchloride unplasticized (PVC-U); Projected width 145 mm; Structural depth 76 mm; Sash: Designation 1472E - sash; Cross section (W x T) 107 mm x 76 mm; Thickness of infill 50 mm; Edge cover of infill 17 mm; Reinforcement: Designation DS01092; Material Steel, galvanized; Cross section (W x T) 35 mm x 40 mm; Frame: Designation 1471E - frame; Cross section (W x T) 66 mm x 147 mm (73 mm x 147 mm including cover profile); Reinforcement: Designation DS01091, DS01091, DS01089-K; Material Steel, galvanized; Cross section (W x T) 8.5 mm x 40 mm, 8.5 mm x 40 mm, 15 mm x 40 mm; Additional profile: Designation Cover profile; Material Polyvinylchloride unplasticized (PVC-U); Cross section (W x T) 38 mm x 73 mm; Additional profile: Designation Sliding profile; Material Aluminium alloy - anodised - painted - powder coated; Cross section (W x T) 18 mm x 33 mm
Special features	

Result

Thermal transmittance according to EN 12412-2:2003-07



$$U_f = 1.4 \text{ W/(m}^2\text{K)}$$

ift Rosenheim
23.11.2021



Konrad Huber, Dipl.-Ing. (FH)
Head of Testing Department
Building Physics



Stefan Junker, Dipl.-Ing. (FH)
Operating Testing Officer
Building Physics


Basis *)

EN 12412-2:2003-07

*) and corresponding national versions
(e.g. DIN EN)

Test report: 21-002514-PR02 PB-
K20-06-en-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 5A1-752BE